



Pimpri Chinchwad Municipal Corporation
Pimpri, Pune - 411018.
Phone :- 020- 67331110/1120
Fax :- 020- 27425600
E-Mail :- commissioner@pcmcindia.gov.in
Web :- www.pcmcindia.gov.in

No - WS/lab/1893/2023

Date - 02/06/2023


To,
The Principal,
Gayatri English Medium School,
Moshi.

Subject: Water sample Potability Certificate.

Drinking water sample provided by Gayatri English Medium School, Moshi on Date: 29/05/2023 was analyzed for Chemical and Bacteriological analysis. As per the analysis reports no. ws /lab /1889/2023 dated 30/05/2023 & ws /lab /1891/2023 dated 02/06/2023 the water Sample is safe for drinking purpose.

The Bacteriological & chemical analysis reports are attached herewith.

Note-The water sample not drawn by this laboratory.


Chief Chemist
Pimpri Chinchwad Municipal Corporation
Pimpri -18

PIMPRI CHINCHWAD MUNICIPAL CORPORATION



(W/S) DIVISION

Report Of Chemical Examination Of Water

NO-WS / LAB / 1889 / 2023

DATE - 30 / 05 / 2023

NAME - माथती इंग्लिश मिडियम

DATE OF RECEIPT - 29 / 05 / 2023

ADDRESS - मोशी

DATE OF EXAMINATION - 29 / 05 / 2023

SOURCE Pcmc water

NO	TESTS	I.S Standards for Drinking Water	Result mg/lit	Result mg/lit	Conclusion
1	Turbidity	1 N.T.U Max	0.75 NTU		
2	pH	6.5 to 8.5	6.73		
3	Total Hardness (as CaCO3)	200 mg/lit	76 mg/lit		
4	Chloride	250 mg/lit	22 mg/lit		
5	Calcium	75 mg/lit	16.03 mg/lit		

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY

CHIEF CHEMIST
Water treatment plant
sector 23 Nigdi

PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(w/s) DIVISION

No-WS/LAB/1891/2023.

Date-02/06/2023.

REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER

NAME- भायत्री इंग्लिश मिडियम स्कूल.

DATE OF EXAMINATION-29/05/2023.

ADDRESS- मोर्शी.

SOURCE - PCMC Water.

NO.	WATER SAMPLE (PLACE)	RESIDUAL CHLORINE (PPM)	CONCLUSION MPN/100ml		REMARK
			Coliforms	E.Coil	
1	Water Sample.	0.2 ppm	0/100ml	-	Potable.
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					


CHIEF CHEMIST
Water Treatment Plant
Pimpri Chinchwad Municipal Corp.
Nigdi, Pune 44

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY



PIMPRI CHINCHWAD MUNICIPAL CORPORATION
PIMPRI – 411 018

Email – healthho@pcmcindia.gov.in Website – www.pcmcindia.gov.in
Phone no. 020 – 67333333 -1336

No. E/Health/5/WS/180/2023

Date:-12/08/2023

To,
Gayatri English Medium School & JR. College
Gandharvnagri, Moshi
Pcmc, Pune - 412105

SCHOOL SANITATION CERTIFICATE

This is to certify that, the E Zone Health Department of Pimpri Chinchwad Municipal Corporation, Pimpri, Pune - 411018 has inspected the premise of **Gayatri English Medium School & JR. College** situated at Moshi, Pune on Dt.11/07/2023 and found that the sanitation requirements for educational institution are as per the norms of Pimpri Chinchwad Municipal Corporation, Development Control Rules.

This certificate is valid for the period of ~~one year~~ one year from the date of issue.



Asst. Commissioner
Pimpri Chinchwad Municipal Corporation
Pimpri - 411 018